

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:48 pm

**PWS ID:** UTAH24039      **Name:** SIMPLOT PHOSPHATE MINE  
**Legal Contact:** SIMPLOT PHOSPHATE MINE      **Rating:** Approved  
JOHN B SPENCER      **Rating Date:** 04/09/1996  
**Address:** 9401 N HWY 191      **Activity Status:** Active  
VERNAL, UT 84078  
**Phone Number:** 435-621-2629  
**City Served (Area):**  
**County:** UINTAH COUNTY  
**System Type:** Non Transient      **Last Inv Update:** 03/02/2011      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 10/15/2009      **Total Dsgn Cap:**  
**Population:** 40      **Surveyor:** ROBERT HART      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day    Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	SPENCER, JOHN B		435-781-3348	435-781-3348	john.spencer@simplot.com

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Industrial	Unknown	0	3
			3 Total Svc Connections

### Storage

**Total Storage:** 2,500 GAL      **Number of Units:** 1      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	RESERVOIR	Ground	2,500 GAL	Fiberglass		A	NO

### Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	ABANDONED		I	

### Distribution System

Pump Type	Total Dyn Head		Pressure Adequate	Cross Connection	Auhority Statement
	ft H2O	P.S.I.			
No					

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL SM-E1	Active	WL	6	25 GPM	20 GPM	Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.